

Upper Reservoir Augmentation Log

Fall Date: 10/28/2024

Spring Date: _____

Spring Configuration

| <u>(In)</u> <u>Tape</u> | <u>(AF)</u> <u>Release</u> | <u>(Ft)</u> <u>Gauge</u> | <u>May 1 - Sept 30</u> | <u>(Ft)</u> <u>Gauge</u> |
|----------------------------|-------------------------------|-----------------------------|------------------------|-----------------------------|
| 24.84 | 0 | 9.83 | 5" STOPLOG 1 | 9.83 |
| 29.88 | 0.76 | 9.41 | 5" STOPLOG 2 | |
| 34.8 | 1.48 | 9 | 5" STOPLOG 3 | 8.83 |
| 39.84 | 2.19 | 8.58 | 7" STOPLOG 4 | |
| 46.8 | 3.12 | 8 | 5" STOPLOG 5 | 7.83 |
| 51.84 | 3.77 | 7.58 | 7" STOPLOG 6 | |
| 58.8 | 4.6 | 7 | 5" STOPLOG 7 | 6.83 |
| 63.84 | 5.19 | 6.58 | 7" STOPLOG 8 | |
| 70.8 | 5.91 | 6 | 5" STOPLOG 9 | 5.83 |
| 75.84 | 6.41 | 5.58 | 7" STOPLOG 10 | |
| 82.8 | 7 | 5 | 5" STOPLOG 11 | 4.83 |
| 87.84 | 7.41 | 4.58 | 7" STOPLOG 12 | |
| 94.8 | 7.85 | 4 | 5" STOPLOG 13 | 3.83 |
| 99.84 | 8.14 | 3.58 | 7" STOPLOG 14 | |
| 106.8 | 8.43 | 3 | 5" STOPLOG 15 | 2.83 |
| 111.84 | 8.62 | 2.58 | 7" STOPLOG 16 | |
| 118.8 | 8.66 | 2 | 5" STOPLOG 17 | 1.83 |
| 123.84 | 8.66 | 1.58 | 7" STOPLOG 18 | |
| 130.8 | 8.66 | 1 | 5" STOPLOG 19 | 0.83 |
| 135.84 | 8.66 | 0.58 | 7" STOPLOG 20 | |
| 142.8 | 8.66 | 0 | | |

Fall Configuration

| <u>Fall</u> <u>Logs</u> | <u>Oct 1 - April 30</u> |
|----------------------------|-------------------------|
| X | 5" STOPLOG 1 |
| X | 5" STOPLOG 2 |
| | 5" STOPLOG 3 |
| | 7" STOPLOG 4 |
| | 5" STOPLOG 5 |
| | 7" STOPLOG 6 |
| | 5" STOPLOG 7 |
| | 7" STOPLOG 8 |
| | 5" STOPLOG 9 |
| | 7" STOPLOG 10 |
| | 5" STOPLOG 11 |
| | 7" STOPLOG 12 |
| | 5" STOPLOG 13 |
| | 7" STOPLOG 14 |
| | 5" STOPLOG 15 |
| | 7" STOPLOG 16 |
| | 5" STOPLOG 17 |
| | 7" STOPLOG 18 |
| | 5" STOPLOG 19 |
| | 7" STOPLOG 20 |

Fall Release

Gauge Before 9.83 ft

Gauge After 9'00 ft

Spring Capture

Gauge Before _____

Maintenance

Lube Stop Logs?

Spring Fall

Comments

House Creek was still flowing over the logs.